



- NOTES:**
1. ALL CABLE AND CONDUIT ENTRIES INTO JUNCTION BOXES TO BE SEALED.
  2. WATER METER TO BE INSTALLED IN ACCORDANCE WITH DEPARTMENT OF WATER'S 'GUIDELINES FOR WATER METER INSTALLATION 2009'
  3. BORE CASING TO BE 200mm UNLESS OTHERWISE AGREED AND APPROVED BY THE MANAGER OF LAND AND DEVELOPMENT INFRASTRUCTURE.
  4. FINAL PIPE SIZES TO CONSIDER THE REQUIRED FLOW RATES, AND BE APPROVED BY THE MANAGER OF LAND AND DEVELOPMENT INFRASTRUCTURE, PRIOR TO INSTALLATION.
  5. DRAWING TO BE READ IN CONJUNCTION WITH THE CITY'S IRRIGATION SPECIFICATION & BORE CONSTRUCTION SPECIFICATION DOCUMENTS.
  6. \*MODEL MUST BE APPROVED BY DEPARTMENT OF WATER AND ENVIRONMENTAL REGULATION (DWER) IN ACCORDANCE WITH THEIR PATTERN APPROVAL DOCUMENTATION

BORE CASING SIZE	DISCHARGE ASSEMBLY SIZE
100mm	50 $\phi$
155mm	80 $\phi$
200mm	100 $\phi$

REVISIONS			
NO.	DESCRIPTION	DATE	SIGNED
D	ADDITIONAL INFORMATION INCLUDED	20.05.20	J.H.
C	DRAWING UPDATED TO SUIT DWER SPECIFICATIONS	01.10.19	J.H.
B	MODIFICATIONS MADE	23.05.05	K.S.
A	ORIGINAL ISSUE	05.07.03	J.H.

**CITY OF ROCKINGHAM STANDARD DRAWINGS**

TITLE:  
**BORE HEADWORKS WITH DOSING TEE AND SUSTAINING VALVE**



PO Box 2142  
 Rockingham DC  
 WA 6169  
 TELEPHONE: (08)9528 0333  
 FAX: (08) 9592 1705

DESIGN	J. HENSON
DRAWN	E. LEWIS
CHECKED	N. WATKINSON
APPROVED	J. HENSON
DRAWING NO.	COR_IRR-01
REV.	D

A3  
 NOT TO SCALE