

**General provisions**

1. Unless provided for in this LDP, the provisions of City of Rockingham Town Planning Scheme No. 2, State Planning Policy 3.1: Residential Design Codes ('R-Codes') and the North-East Baldvis Local Structure Plan apply.
2. Development approval is not required, but a building permit is required, for the construction of a dwelling anywhere within the LDP area unless a variation to this LDP is being sought.
3. There is no requirement to consult with adjoining or other landowners where construction in accordance with this LDP is proposed.
4. All lots within LDP area are subject to City of Rockingham's Planning Policy 3.2.22 - Medium-Density Single House Standards (R-MD Codes)

**Noise-affected lots**

5. Quiet House construction requirements are applicable to all noise-affected lots identified on this LDP.

Modifications to these Quiet House requirements may be approved by the City of Rockingham where it can be demonstrated that the proposed development will be provided an acceptable level of acoustic amenity, and subject to the proposal development being accompanied by a Transport Noise Assessment undertaken by a suitably-qualified consultant.

**Vehicle Access**

6. Vehicular access to onsite car parking spaces is permitted from the primary street frontage, and garage locations may be provided where identified on this LDP.



**LEGEND**

	LDP Boundary
	R25
	Preferred Garage Location
	POS

**QUIET HOUSE DESIGN**

	Upper Floor - Package A Ground Floor - Not Required
	Upper Floor - Package B Ground Floor - Not Required
	Upper Floor - Package B Ground Floor - Package A
<b>NOISE BARRIER</b>	
	Noise Wall (to be constructed by Cedar Woods)

**ENDORSEMENT TABLE**

	2/9/2025
Manager Statutory Planning, City of Rockingham	Date
This Local Development Plan has been approved by Council under clause 52(1)(a) of the deemed provisions of Town Planning Scheme No.2.	



### Quiet House Package B

59-62 dB  $L_{Aeq}(\text{Day})$  & 54-57 dB  $L_{Aeq}(\text{Night})$

Element	Orientation	Room	
		Bedroom	Indoor Living and Work Areas
External Windows	Facing	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 31</math>):               <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 6mm glass or 6mm-12mm-6mm double insulated glazing.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 34</math>):               <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 10mm glass or 6mm-12mm-10mm double insulated glazing.</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 28</math>):               <ul style="list-style-type: none"> <li>Sliding or double hung with 6mm-12mm-10mm double insulated glazing;</li> <li>Sealed awning or casement windows with minimum 6mm glass.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 31</math>);</li> <li>Up to 80% floor area (<math>R_w + C_{tr} \geq 34</math>).</li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	As above, except $R_w + C_{tr}$ values may be 6 dB less or max % area increased by 20%.	
External Doors	Facing	<ul style="list-style-type: none"> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 31</math> rated door and frame including seals and 10mm glass.</li> </ul>	<ul style="list-style-type: none"> <li>Doors to achieve <math>R_w + C_{tr} \geq 28</math>:               <ul style="list-style-type: none"> <li>40mm Solid timber core hinged door and frame system certified to <math>R_w 32</math> including seals;</li> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 28</math> rated door and frame including seals and 6mm glass.</li> </ul> </li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	As above, except $R_w + C_{tr}$ values may be 6 dB less or max % area increased by 20%.	
External Walls	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 50</math>:               <ul style="list-style-type: none"> <li>Two leaves of 90mm thick clay brick masonry with minimum 50mm cavity between leaves and 25mm glasswool or polyester (<math>24\text{kg/m}^3</math>). Resilient ties used where required to connect leaves.</li> <li>Two leaves of 110mm clay brick masonry with minimum 50mm cavity between leaves and 25mm glasswool or polyester insulation (<math>24\text{kg/m}^3</math>).</li> <li>Single leaf of 220mm brick masonry with 13mm cement render on each face.</li> <li>150mm thick unlined concrete panel or 200mm thick concrete panel with one layer of 13mm plasterboard or 13mm cement render on each face.</li> <li>Single leaf of 90mm clay brick masonry with:                   <ul style="list-style-type: none"> <li>A row of 70mm x 35mm timber studs or 64mm steel studs at 600mm centres;</li> <li>A cavity of 25mm between leaves;</li> <li>50mm glasswool or polyester insulation (<math>11\text{kg/m}^3</math>) between studs; and</li> <li>One layer of 10mm plasterboard fixed to the inside face.</li> </ul> </li> </ul> </li> </ul>	
Roofs and Ceilings	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 35</math>:               <ul style="list-style-type: none"> <li>Concrete or terracotta tile or metal sheet roof with sarking and at least 10mm plasterboard ceiling with R3.0+ fibrous insulation.</li> </ul> </li> </ul>	

### Quiet House Package A

56-58 dB  $L_{Aeq}(\text{Day})$  & 51-53 dB  $L_{Aeq}(\text{Night})$

Element	Orientation	Room	
		Bedroom	Indoor Living and Work Areas
External Windows	Facing	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 28</math>):               <ul style="list-style-type: none"> <li>Sliding or double hung with minimum 10mm single or 6mm-12mm-10mm double insulated glazing;</li> <li>Sealed awning or casement windows with minimum 6mm glass.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 31</math>):               <ul style="list-style-type: none"> <li>Sealed awning or casement windows with minimum 6mm glass.</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 25</math>):               <ul style="list-style-type: none"> <li>Sliding or double hung with minimum 6mm single or 6mm-12mm-6mm double insulated glazing;</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 28</math>);</li> <li>Up to 80% floor area (<math>R_w + C_{tr} \geq 31</math>).</li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	No specific requirements	
External Doors	Facing	<ul style="list-style-type: none"> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 28</math> rated door and frame including seals and 6mm glass.</li> </ul>	<ul style="list-style-type: none"> <li>Doors to achieve <math>R_w + C_{tr} \geq 25</math>:               <ul style="list-style-type: none"> <li>35mm Solid timber core hinged door and frame system certified to <math>R_w 28</math> including seals;</li> <li>Glazed sliding door with 10mm glass and weather seals.</li> </ul> </li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less.	
	Opposite	No specific requirements	
External Walls	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 45</math>:               <ul style="list-style-type: none"> <li>Two leaves of 90mm thick clay brick masonry with minimum 20mm cavity; or</li> <li>Single leaf of 150mm brick masonry with 13mm cement render on each face; or</li> <li>One row of 92mm studs at 600mm centres with:                   <ul style="list-style-type: none"> <li>Resilient steel channels fixed to the outside of the studs; and</li> <li>9.5mm hardboard or fibre cement sheeting or 11mm fibre cement weatherboards fixed to the outside;</li> <li>75mm thick mineral wool insulation with a density of at least <math>11\text{kg/m}^3</math>; and</li> <li>2 x 16mm fire-rated plasterboard to inside.</li> </ul> </li> </ul> </li> </ul>	
Roofs and Ceilings	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 35</math>:               <ul style="list-style-type: none"> <li>Concrete or terracotta tile or metal sheet roof with sarking and at least 10mm plasterboard.</li> </ul> </li> </ul>	